



Lloyd's Register Marine Division  
Lloyd's Register House  
29 Wellesley Road  
Croydon, CR0 2AJ, UK  
Telephone +44 181-681 4040  
Fax +44 181-681 6814

Elomek Forsaljnings AB  
Kvarnhagsgatan 4  
S-165 54 Hasselby  
Stockholm  
Sweden

Direct dial:

Our ref: TAD/40896/99/AEM/  
O-17596

Your ref:

Date: 17 November 1999

**TO WHOM IT MAY CONCERN**

**ELOMEK FORSALJNINGS AB  
CERTIFICATE NO. 88/00172(E2)  
MED CERTIFICATION FOR FIRE DOOR HOLDERS**

Reference LR Type Approval Certificate No. 88/00172(E2).

The fire Door Holder is a component. The Marine Equipment Directive (MED) 96/98/EC 20 December 1996 as amended by 98/85/EC 11 November 1998 applies to systems not components. There is no requirement for the Elomek Electromagnetic doorholder to be approved to the MED.

The LR Type Approval provides third party attestation that the product meets the manufacturer's specification.

A.E. McLaughlin  
Type Approval Department, Extn. 4722

TL

## Memorandum

To MARGARETA BRITTING Fax  
LR STOCKHOLM

From AI RUFAIE Pages 1 of 1  
LDSS/PAS/TYPE  
APPROVAL

Subject ELOMEK  
FIRE DOOR HOLDERS  
MARINE EQUIPMENT DIRECTIVE

Date **Sunday 29 April 2007**

Your -  
ref

Our DAPP/PAS/MED/0000001/MHR/  
ref O-81167

1. Reference your email message dated 06 November 2006 with attachments.
2. The letter sent to the client by Anthony McLaughlin dated 17 November 1999 still apply.
3. The MED refers to systems and not components such as a handle. Hence MED Certification is not required.

Best Regards,

**M. Al Rufaie**

M.H.A. RUFAIE  
Senior Electrical Engineer  
Product-Approval / London Design Support Services  
Tel: +44 (0) 20 7423 1849 (*Direct line*)  
Email: [product-approval@lr.org](mailto:product-approval@lr.org) / [al.rufaie@lr.org](mailto:al.rufaie@lr.org)

Overtyping this paragraph to use the full width Book Antiqua version (delete the paragraph not in use).